ERI CONSULTING, INC.

P. O. Box 2024, Tyler, Texas 75710
2026 Republic Drive, Suite A, Tyler, Texas 75701
Ph. (903) 534-5001 Fax (903) 534-8701
TBPE Firm # F-1787
www.ericonsulting.com

September 30, 2013

Wal-Mart Stores, Inc. #8085
c/o Ms. Vicki Ingram
2001 SE 10th Street
Bentonville, AR 72716

RE: ES#06-1010, Asbestos Survey, Wal-Mart Store #131, 2311 South Jefferson, Mt. Pleasant, Texas
RE-INSPECTION

Dear Ms. Ingram:

We originally performed a comprehensive survey at this store on March 31, 2006. I have reviewed the inspection report and laboratory findings, and found the report to be adequate as of the inspection date. However, whenever renovation activities are performed, and new building materials are introduced to the store, an existing report is no longer considered "comprehensive." In such cases, further sampling of these new suspect materials would be necessary to confirm/deny the presence of asbestos-containing materials. Therefore, we re-inspected the store, sampling only those materials which had been added during renovations since our 2006 survey. This sampling was performed by Mr. BJ Berry Jr. of our office, TDSHS License No. 60-3022, on September 24, 2013.

To summarize the current inspection, 42 bulk samples were collected and analyzed by Polarized Light Microscopy (PLM) in our TDSHS licensed laboratory (TDSHS License No. 30-0007). All were confirmed to be non asbestos-containing.

Current EPA and Texas Department of State Health Services regulations require that an asbestos survey be performed prior to disturbing building materials (demolition or renovation) in a public building. TDSHS regulations require that a notification be filed only if structural members are removed, or asbestos-containing materials are disturbed. TDSHS does not require nor desire copies of the survey report to be filed with them.

TDSHS regulations require that a copy of the asbestos survey be kept on the job site at all times during renovation activities. Senate Bill 509 requires facility owners to provide proof of asbestos survey to city building officials prior to building permits being issued.

In summary, no confirmed asbestos-containing materials were found in Wal-Mart Store #131, 2311 South Jefferson, Mt. Pleasant, Texas, either in our 2006 survey or the current re-inspection. No further action with regard to asbestos-containing materials is required for this store, as long as further renovation activities are not performed which would alter the sampling documentation in our report. Please find enclosed the (1) bulk sample log, (2) sample location diagram, (3) laboratory analysis report, (4) our credentials, and (5) a copy of our original asbestos survey. We have enjoyed working with you on this matter. If you have questions concerning the information submitted, or if we may be of further service to you, please contact our office at 1-800-542-7248.

Sincerely,

Christopher L. Power
Vice President
TDSHS License No. 10-3566
Expires 2/15/2015