response to Complaint number 2328412.

Interstate Commerce:
Walmart, Store# 131, is in the retail industry, use product Hisense Roku TV QLED model are manufactured in Suwanee, Geogia. SN Unreadable.

Opening Conference:
On August 19, 2025, an opening conference was conducted with Devin Wallace Store Manager Assistance in person. Upon arrival, the compliance safety and health officer presented credentials and explained the nature and scope of the inspection in detail. The employer concurred with the scope of the inspection. CSHO(s) informed them of the need to take photographs, measurements, and interviews with employees.

Inspection Walk-around:
On August 19, 2025: The employer participated in the walk-around of the inspection. The walk-around proceeded in accordance with the FOM.

Inspection Findings:

On August19, 2025, CSHO was unable to substantiate any hazards during the investigation.

1. Electrical arcing from roofing work in the electronics department:

   Management provided work order requests for repairs for the electrical hazard in the Electronics department and showed closed.



Issue details

Closed

The issue has been completed.



Damaged Conduit Or Exposed Wiring Has Power - Damaged - No Hurry

Gmt complete

Details | History

Issue summary

Date reported	Tue Jul 29, 2025
Issue	Has Power - Damaged - No Hurry
Location	General Merchandise/sales Floor
Store contact number	903-572-0018
Description	Old light fixture above electronics started smoking and burned through the roof
Assigned to	(b) (7)(C)
Watchlist	Management

Create — Approve — Pending — In progress — Closed